

Stallholder Name: _____

LP GAS SAFETY - Must be completed by all stallholders using LPG, including barbecues		Y	N	ACTION IF NO
APPLIANCES	Only certified appliances in use			
Your stallholder site is an extension of your workplace. Stallholders must ensure: <ul style="list-style-type: none"> documented procedures for various tasks associated with the use of LP Gas are in place all personnel carrying out these tasks are adequately trained records are kept to demonstrate personnel have received instructions in the specific safe method 	Service history available			
	In good working condition			
	Safety devices not tampered with			
	Taps & knobs in good condition and marked			
	Not on a combustible surface			
	In a well vented location			
	Clearances from LPGas cylinder			
	External appliances not in an internal location			
	Appliance pressure does not exceed 3 kPa			
	REGULATORS & HOSES	Hoses for appliance acceptable		
	Regulators in good condition			
	Regulator hose of approved material			
	Hoses in good condition			
	Protected from accidental damage			
	Hoses less than 3m in length			
CYLINDERS	Cylinder within 10-year test date			
	Cylinder in good condition			
	Cylinder connections checked for leaks			
	Located away from flammable materials and ignition source			
	Cylinder not blocking exit or path of travel			

Contact Details: Provide name & mobile number of a staff member on-site during the F.O.O.D. Week Night Markets.

Name: _____ Mobile: _____

This statement indicates that I/we, the stallholder have implemented the following control measures for our site and activities at the 2020 F.O.O.D. Week Night Markets to be held Friday 27th March, 2020.

Person responsible: _____ Signed: _____

Position: _____ Date: _____